



DURHAM DISTRICT SCHOOL BOARD

ADDENDUM #3

**FOR ALL BIDDERS
FOR
TENDER T23-34
INTERIOR RENOVATIONS AND VENTILATION UPGRADES**

**AT
R.S. MCLAUGHLIN C.V.I.
570 Stevenson Road North, Oshawa, ON L1J 5P1
Tel: 905-728-9407**

Date Issued: May 11, 2023

Please review the following addendum and clarification. This document shall be considered a component of Request for Tender package **T23-34**. All other terms and conditions remain the same.

1) Dust Collector Unit Make and Model to be confirmed.:

- Contractor to submit complete shop drawings immediately upon award of the Contract.
- Shop drawings must demonstrate the blower and exhaust system are designed in accordance with NFPA 91, "Standard for Exhaust Systems for Air Conveying of Vapors, Gases, Mists, and Noncombustible Particulate Solids"; for immediate submission to the Authorities Having Jurisdiction.
- Make and Model to be indicated on the Revised Appendix A - Itemized Pricing (attached)

End of Addendum #3